



Pressure Test To ISO5208			
DN	Pressure Rating(PN)	Hydro-Test Pressure(Mpa)	
		Body	Seat
40-300	25	3.75	2.75

1. Design According to :DIN3352.
2. Face to Face Dimension according to DIN3202-F4/EN558-1 14.
3. Flange drilling according to EN1092-2 PN25
4. Test According to ISO 5208.

Size	L	ΦD	ΦD1	ΦD2	b	n-Φd1	H(Max)	W
40	140	150	110	84	19	4-19	250	180
50	150	165	125	99	19	4-19	278	180
65	170	185	145	118	19	8-19	283	180
80	180	200	160	132	19	8-19	326	200
100	190	235	190	156	19	8-23	373	200
125	200	270	220	184	19	8-28	420	200
150	210	300	250	211	20	8-28	460	280
200	230	360	310	274	22	12-28	571	320
250	250	425	370	330	24.5	12-31	673	320
300	270	485	430	389	27.5	16-31	750	450

No	Part Name	Material	Q'ty	Remarks
16	Handwheel	Ductile iron		
15	Bolt	Galvanized steel		
14	Washer	Galvanized steel		
13	Bushing Nut	Brass		
12	O Ring	EPDM		
11	O Ring	EPDM		
10	Washer	Nylon		
9	V Ring	EPDM		
8	Bolt Cover	PE-Rubber		
7	Bolt	Galvanized steel		
6	Bonnet	Ductile iron GGG50		
5	Bonnet Gasket	EPDM		
4	Disc nut	Brass		
3	Stem	SS420		
2	Disc	Ductile iron+ EPDM		
1	Body	Ductile iron		

DRN	wang	WEIGHT		MATERIAL
CHK		SCALE		Resilient Gate Valve
APP		DATE	07/25/2024	
				CZ0005
				REV

This document is the property of Huihua Valve Industry Co. Distribution of this document without the written consent of the owner is strictly forbidden. Failure to comply will incur a liability for damages.

http://www.hiwa.cn Website sales@hiwa.cn Email

86 - 533 - 6077200 Phone 86 - 533 - 6077233 FAX

Huihua Valve Industry co. No.36 MinAn Road New Hi-Tech Industry Zone Zibo Shandong China 255088 p.c